

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-1591:162 Page 1 of 1

CATEGORY: Misc. Devices/Control Unit Accessories

LISTEE: Edwards Systems Technology, 6411 Parkland Drive, Sarasota, FL 34243
Contact: Leon Newsome (941) 739-4276 Fax (941) 739-4334

DESIGN: Color Graphic Package Models CGP-1, CGP-1-R, CGP-1/220 and CGP-1-R/220; CGP-4, CGP-4-R, CGP-4/220 and CGP-4-R/220; CGP-8, CGP-8-R, CGP-8/220 and CGP-8-R/220; and Computerized Color Annunciators Models CCA-1, CCA-1-R, CCA-1/220, CCA-1-R/220, CCA-4, CCA-4-R, CCA-4/220 and CCA-4-R/220; CCA-8, CCA-8-R and CCA-8-R/220. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number and UL label.

APPROVAL: Listed as color graphic packages when used with separately listed compatible fire alarm control unit. When used with a proprietary system, a Model PT-1-P parallel printer and a UPS listed for fire protective signaling use must be used.

NOTE: Formerly 7300-1102:117, 7300-1388:172

11-02-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 17, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager